



Ref. Certif. No.

**SG PSB-LE-06541**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic controlgear for LED modules Electronic Converter for LED
Name and address of the applicant	<b>Vossloh-Schwabe Deutschland GmbH</b> Stuttgarter Straße 61/1 73614 Schorndorf GERMANY
Name and address of the manufacturer	Vossloh-Schwabe Deutschland GmbH Stuttgarter Straße 61/1, 73614 Schorndorf, GERMANY
Name and address of the factory	[REDACTED]
Ratings and principal characteristics	Details please see page 2
Trademark / Brand (if any)	Details please see page 2
Model/type Ref.	ECXe700.729 Ref.-No.187566, ECXe1050.730 Ref.-No.187567
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015 IEC 61347-1:2015/AMD1:2017 IEC 61347-2-13:2014 IEC 61347-2-13:2014/AMD1:2016
as shown in the Test Report Ref. No. which forms part of this certificate	087-2500111-000

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 049606 0070 Rev. 00

Date, 2025-03-12

( Yin Ji )

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore



Ref. Certif. No.

SG PSB-LE-06541

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)



Ratings and principal characteristics

Rated voltage:	220-240V~ or 176-276VDC
Rated frequency:	0/50/60Hz
Rated input current:	See model list
Rated output:	See model list
Type of output:	Constant current type
Protection against electric shock:	SELV
ta:	-20~45°C
tc:	See model list
Temperature declared thermally protected:	110°C
Protection class:	classII (for independent use)
Degree of protection:	IP20
Method of installation:	Independent (with end-cap) or Built-in (without end-cap)

Model list:

Model	Supply current (A)	P <sub>rated</sub> (W)	Output current (A)	tc (°C)
ECXe700.729 Ref.-No.187566	0,130-0,160	29,4	0,35-0,7, each step 50mA	80
ECXe1050.730 Ref.-No.187567	0,190-0,240	44,1	0,7-1,05, each step 50mA	85

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 049606 0070 Rev. 00

Date, 2025-03-12

  
( Yin Ji )

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore