

CERTIFICATE

Issued to:
Applicant:
Vossloh-Schwabe Deutschland GmbH
Stuttgarter Str. 61/1
73614 Schorndorf, Germany

Licensee:
Vossloh-Schwabe Deutschland GmbH
Stuttgarter Str. 61/1
73614 Schorndorf, Germany

Product : Electronic Controlgear for LED
Trade name(s) : VS LIGHTING SOLUTIONS
Type(s)/model(s) : ECXe 1050.720, ECXe 600.718 and ECXe 800.719

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 61347-1:2015, EN 61347-1:2015/A1:2021, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017 and EN IEC 62384:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6061104


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 18 December 2024 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-151352

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



Matilde Tonsi
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Electronic Controlgear for LED
Trade name(s)	: VS LIGHTING SOLUTIONS
Type(s)/model(s)	: ECXe 1050.720, ECXe 600.718 and ECXe 800.719
Rated voltage	: 220-240 V
Rated frequency	: 50/60 Hz
Degree of protection	: IP20
Ta	: 35 °C
Tc	: 70 °C
Additional information	: Built-in type, double insulation, non-inherently shorted circuit proof, 110 °C thermal protection, SELV constant current output

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-1:2015/A1:2021
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN IEC 62384:2020

Test result


The test results are documented in DEKRA test file 492878000.

Additional information

The list of components is laid down in test report 4928780.50,4928780.51.

Conclusion

The examination has confirmed that all requirements were met.

Factory location

Trade name : VS LIGHTING SOLUTIONS stands for

