



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	LED Power Supply
Name and address of the applicant	Vossloh-Schwabe Deutschland GmbH Stuttgarter Str. 61/1, 73614 Schorndorf, Germany
Name and address of the manufacturer	Vossloh-Schwabe Deutschland GmbH Stuttgarter Str. 61/1, 73614 Schorndorf, Germany
Name and address of the factory	
<i>When more than one factory</i>	<input type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	Product data Ratings: 220-240 V~, 50/60 Hz, λ : 0,95, Independent type, Class I, IP67, SELV, constant voltage output, thermal protected 110 °C,tc: 85 °C,Urated 24 Vd.c. Product data – type EDXd1150/24.101 Ratings: In max. 0,9 A, Irated max. 6.25 A, Prated Max. 150 W, ta: 55 °C Product data – type EDXd145/24.099 Ratings: In max. 0,3 A, Irated max.1,88 A, Prated max. 45 W, ta: 60 °C Product data – type EDXd180/24.100 Ratings: In max. 0,6 A, Irated max. 3,33 A, Prated max. 80 W, ta: 60 °C
Trademark / Brand (if any)	 VS LIGHTING SOLUTIONS
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	EDXd1150/24.101, EDXd145/24.099 and EDXd180/24.100
Additional information	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014 and IEC 61347-2-13:2014/AMD1:2016 National differences: AU, EU Group Differences, GB, NZ
As shown in the Test Report Ref. No. which forms part of this Certificate	4929695.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-01-13

Signature: Kreny Lin

