

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

LED Emergency Converter Kit

Name and address of the applicant

Vossloh-Schwabe Deutschland GmbH  
Stuttgarter Strabe 61/1 D-73614 Schorndorf Germany

Name and address of the manufacturer

[REDACTED]

Name and address of the factory

[REDACTED]

*When more than one factory* Additional information on page 2

Ratings and principal characteristics

**Product data**Ratings: Input: 220-240 Vac; 50/60Hz; Constant emergency power: 2,5 W;  
Output voltage: 10-300 Vdc; U-OUT (open circuit voltage): 350 Vdc;  
tc: 70°C; built-in; EL or EL-T type; Discharge time: 3 hours; Battery:  
LiFePO4

Trademark / Brand (if any)

  
VS LIGHTING SOLUTIONS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

EMCc180.028

Additional information

 Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-7:2011,  
IEC 61347-2-7:2011/AMD1:2017 and IEC 61347-2-7:2011/AMD2:2021**National differences:**

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6208515.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
6825 MJ Arnhem  
Netherlands

Date: 2024-12-23

Signature: May Liu