




Ref. Certif. No.

SG PSB-LE-06013

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic controlgear for LED modules Electronic Converter for LED
Name and address of the applicant	Vossloh-Schwabe Deutschland GmbH Stuttgarter Straße 61/1 73614 Schorndorf GERMANY
Name and address of the manufacturer	Vossloh-Schwabe Deutschland GmbH Stuttgarter Straße 61/1, 73614 Schorndorf, GERMANY
Name and address of the factory	
Ratings and principal characteristics	Details see next page
Model/type Ref.	ECXd700.674, ECXd400.675, ECXd600.676, ECXd800.677, ECXd1050.678, ECXd800.693
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015 IEC 61347-1:2015/AMD1:2017 IEC 61347-2-13:2014 IEC 61347-2-13:2014/AMD1:2016
as shown in the Test Report Ref. No. which forms part of this certificate	087-2401532-000

Page 1 of 2
This CB Test Certificate is issued by the National Certification Body

CBS 049606 0044 Rev. 00
Date, 2024-07-31

(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)



Rated voltage: 220-240V~
 Rated frequency: 50/60Hz
 Rated input current: See model list
 Rated output: See model list
 Type of output: Constant current type
 Protection against electric shock: SELV
 ta: -20~45°C
 tc: See model list
 Temperature declared thermally protected: 110°C
 Protection class: II (for independent use)
 Degree of protection: IP20
 Method of installation: Independent (with end-cover) or Built-in (without end-cover)

Model list:

Model	Ref.No.	Supply current (A)	P _{rated} (W)	U _{rated} (VDC)	Output current (A)	U _{out} (V)	tc(°C)
ECXd700.674	187439	0.065-0.085	14	6-20	0.35/0.5/0.55/0.7	60	75
ECXd400.675	187440	0.075-0.1	16.8	20-42	0.25/0.3/0.35/0.4	60	75
ECXd600.676	187441	0.11-0.14	25.2	20-42	0.45/0.5/0.55/0.6	60	75
ECXd800.677	187442	0.165-0.185	34	20-42	0.65/0.7/0.75/0.8	60	75
ECXd1050.678	187443	0.2-0.24	44.1	20-42	0.9/0.95/1.0/1.05	60	85
ECXd800.693	187475	0.18-0.215	40	30-50	0.5/0.6/0.7/0.8	60	85

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 049606 0044 Rev. 00

Date, 2024-07-31



(Yin Ji)

